


NOTES:

1. PRESSURE REDUCING VALVE BODY SHALL BE IRON; SEAT SHALL BE STAINLESS STEEL; INTEGRAL STRAINER SHALL BE STAINLESS STEEL; STEM SHALL BE BRASS; AND, DISK SHALL BE BRASS.
2. ALL BOXES SHALL BE CARSON 1324 OR APPROVED EQUAL.
3. REFER TO CITY STANDARD DETAIL LSD-14 FOR ALL MATERIALS

			CITY OF FREMONT STANDARD DETAILS CITY STANDARD IRRIGATION PRESSURE REDUCTION VALVE			DATE APPROVED BY CITY COUNCIL 04/11/06	
						RESOLUTION NO. 2006-31	
						 CITY ENGINEER	
NO.	REVISED	DATE					
REVISIONS							
FILE NO.	SCALE	DRAWN	CHECKED	DATE	DWG NO.		
LSD-25.DWG	1" = 1'-0"	AK/MM/PM	RER	NOV. 2005	LSD-25	25 of 27	